



Public Works Department – Engineering Division

March 29, 2024

ADDENDUM NO. 2

PROJECT 2028 CRESTVIEW DRIVE SAFETY IMPROVEMENTS

NOTICE TO BIDDERS:

The following clarifications, amendments, additions and/or deletions as set forth herein shall apply to the above project contract documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally specified and/or shown. Submitters shall assure themselves that all addendum changes have been incorporated into their proposal.

A. QUESTIONS

B. ADDITIONS/DELETIONS

C. CLARIFICATIONS

Please be advised of the following clarifications to the contract documents:

1. Please clarify if the demolition and installation quantities for Detail 1 on Sheet 16 are included in the Bid Schedule as it does not appear on the demolition and installation sheets of the plans.

Yes, the demolition and installation quantities for Detail 1 on Sheet 16 are included in the Bid Schedule as bid item 5 and bid item 17.

2. Please clarify if a mockup is required per Section 32 13 13 Part 1.5.

Yes a mockup is required.

3. Please confirm if the median infill is supposed to be textured.

Yes, the infill for all medians shall be stamped concrete, bomanite pattern, and color PS11086 from the Federal Standard color charts. Patterns shall match existing median patterns currently used in the City of Pittsburg.

BIDDERS MUST SIGN AND ATTACH one (1) copy of this addendum document to the proposal as acknowledgment of receipt of these instructions and that said addendum was properly evaluated in the proposal.

ANY PROPOSAL NOT IN COMPLIANCE WITH THIS ADDENDUM MAY BE REJECTED.



Issued: 03/29/24

Dayne Johnson, P.E.
Assistant City Engineer

ADDENDUM NO. 2, PROJECT 2028 CRESTVIEW DRIVE SAFETY IMPROVEMENTS is hereby acknowledged and was considered in this Project Proposal.

Bidder's Signature

Date

Firm Name

Mailing Address

City/State/Zip+4