



---

Public Works Department – Engineering Division

March 29, 2024

**ADDENDUM NO. 2**

**PROJECT 8336 AMERICANA PARK BYPASS CHANNEL**

**NOTICE TO BIDDERS:**

The following clarifications, amendments, additions and/or deletions as set forth herein shall apply to the above project contract documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally specified and/or shown. Submitters shall assure themselves that all addendum changes have been incorporated into their proposal.

**A. ADDITIONS/DELETIONS**

1. None

**B. CLARIFICATIONS**

Please be advised of the following clarifications to the contract documents:

1. Clarification on the shutdown timeframe associated with questions **4, 16, 17, 18** as shown in **Addendum No.1**.

*Response: The City will allow up to a 48 hour window and understands the curing time for the anchor blocks can be reduced with additives.*

*Contractor shall assume that there is a 2 full day (48 hour) window of time the water may be shutdown.*

---

**BIDDERS MUST SIGN AND ATTACH** one (1) copy of this addendum document to the proposal as acknowledgment of receipt of these instructions and that said addendum was properly evaluated in the proposal.

**ANY PROPOSAL NOT IN COMPLIANCE WITH THIS ADDENDUM MAY BE REJECTED.**



Issued: 03/29/24

\_\_\_\_\_  
Dayne Johnson, P.E.  
Assistant City Engineer

**ADDENDUM NO. 2, PROJECT 8336 AMERICANA PARK BYPASS CHANNEL** is hereby acknowledged and was considered in this Project Proposal.

\_\_\_\_\_  
Bidder's Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Firm Name

\_\_\_\_\_  
Mailing Address

\_\_\_\_\_  
City/State/Zip+4