

Phone: (925) 252-4910 Fax: (925) 252-4814

Bathroom / Laundry Counter Receptacles 2016 CEC, Section 210.52 (D)

210.52 (D) Bathrooms. In dwelling units, at least one receptacle outlet shall be installed in bathrooms within (3 ft.) of the outside edge of each basin. The receptacle outlet shall be located on a wall or partition that is adjacent to the basin or basin countertop. EXCEPTION: The receptacle shall not be required to be mounted in the wall or partition where it is installed on the side or face of the basin cabinet not more than (12 in.) below the countertop.

210.52 (F) Laundry Areas. In dwelling units, at least one receptacle outlet shall be installed for the laundry. EXCEPTION (1). In a dwelling unit that is an apartment or living area in a multifamily building where laundry facilities are provided on the premises and are available to all building occupants, a laundry receptacle shall not be required. EXCEPTION (2). In order than one-family dwellings where laundry facilities are not to be installed or permitted a laundry receptacle shall not be required.